PFLS St Boniface Hospital		
McEwan Building	Addendum #6	Section 00 90 00
_		Page 1
Project #24-001-22		Date July 31, 2025

The following revisions are herewith incorporated into the Tender Documents and shall be included in the Tender Price. Where a revision is called for in one drawing or section of the Specification, it shall be considered revised for all related drawings and sections of the Specification. This Addendum shall be returned with other Tender Documents at the time of submission.

This addendum (2 pages) shall form a part of and be included in the Contract Documents for the above titled project and no consideration will be entertained for extras to the Contract due to failure of the contractor to become thoroughly familiar with this addendum.

Signify that Addendum has been received by listing the Addendum number and date in the appropriate spaces on the Tender Form.

## FRONT END SPECIFICATION REVISIONS

- .1 SECTION 00 80 00 PRICING FORM-STIPULATED PRICE- Appendix E Approved Alternatives
  .1 Remove and replace Appendix E with attached form.
  - **End of Addendum**

-----

Provincial Fire and Life Safety Project St. Boniface Hospital – McEwen Building SMS Project No.: 24-001-22

**Issued for Construction** 

Section 00 80 00 PRICING FORM - STIPULATED PRICE

Page 1 of 1

## Appendix E Approved Alternatives

Project:	Provincial Fire and Life Safety Project – St. Boniface - McEwen Building
Bidder:	

The following are Approved Alternatives, which were approved by the Prime Consultant in accordance with Substitution Procedures 00 26 00. The amounts indicated are an addition to, a deletion from, or no change to the Base Bid. Identify the project by the I/O number provided in Section 00 23 13, Paragraph

Amounts do not include the GST, but do include any applicable PST.

Description of Approved Alternative (refer to Section 00 26 00)	Effect on Base Bid (\$)			
(leter to section of 20 of)	Addition	Deletion	No Change	
Construct new 1-hour rated shaft along north wall; remove and reinstall the existing door; patch and make good the wall around the door frame.				
2. Delete speaker/strobes in patient rooms (18 rooms).				
3. Speaker/strobes to be provided in patient rooms (18 rooms). Strobes to be rated at 15 cd instead of 177 cd.				
4. Provide fibre optic cable (4 strand multi-mode) in conduit between new Jace located in HUB room and DDC controller.				
(If no Approved Alternatives, put "Not Applicable" and initial				
bottom of page)				